



City of Austin

PUBLIC WORKS DEPARTMENT

Project Management Division

6800 Burleson Road, Building 312, Suite 200, Austin, TX 78744

DATE: December 2, 2020

PROJECT: Street Rehabilitation Phase 2 IDIQ Project No.3

CIP ID: 12981.004

IFB# CLMC824

SUBJECT: Answers to Bidders' Questions

The following are answers to Bidders' questions received on the above project. These answers do not modify the Bid Documents. Any modifications to the Bid Documents will be through an Addendum.

Q-1: Can we have clarification on the following bid item:

104S-G	REMOVE MISCELLANEOUS P.C. CONCRETE	LS	5	
--------	---------------------------------------	----	---	--

Is this item intended to cover removal of miscellaneous concrete at five locations? If so, can we get some information to quantify the miscellaneous concrete items?

A-1: Yes, this item is intended to cover removal of miscellaneous concrete at five locations as needed. This being an IDIQ contract, specifics are not available at this time. The item is intended to cover removal of concrete items that are not defined under 104S-B or 104S-C.

Q-2: Can we have clarification on the following bid item:

803S-CD	BARRICADES, SIGNS AND TRAFFIC HANDLING	CD	20	
---------	---	----	----	--

The Initial Term is 12 Months but there is only 20 CD on the bid form. Is it the intention to complete the work in 20 CD?

A-2: The intent is to complete the work in a total of approximately 20 calendar days over a 12-month period at multiple locations.

Q-3: Can we have clarification on the following bid item:

871S-D	REFLECTORIZED TYPE I THERMOPLASTIC PAVEMENT MARKINGS 4 INCHES, 100 MILS IN THICKNESS, WHITE IN COLOR	EA	10	
--------	--	----	----	--

Usually this item is paid by the LF. Can we get a defined length if this is paid by the each?

A-3: Item 871S-D refers to the symbols and are paid for by the number of symbols placed, i.e. "each".